

Kawartha Lakes, Septic Use Permit and Diagram



SEWAGE SYSTEM INSPECTION REPORT AND USE PERMIT

E-16-
FILE NUMBER

REPORT

DATE July 26

INSTALLED BY: KORNE BAGSMAN

Work authorized by certificate of approval has been satisfactorily completed and includes.

- Septic Tank Holding Tank of working capacity of 3600 litres constructed of steel/concrete/fiberglass on site or prefabricated to serve 3 bedrooms STANDARD


- Distribution Pipe. Type PVC Clay Tile Other _____ Absorption Trench System RAISED

Filter Bed System Filter Bed Area _____ sq. m.; Contact Area _____ sq. m.

Total 75 Linear Metres in 6 runs of 12.4 metres and fed by gravity Siphon or Pump

- Other Details _____

Actual location and orientation of components of sewage system are as shown hereunder or as outlined on the Certificate of Approval form



SCALE 1 square equals approx. _____

The following work remains to be completed Backfill system and sod or seed Stabilize all sloped surfaces Finish grading to shed run-off around leaching bed Other CURB END OF BED TO PREVENT VEHICLE TR

USE PERMIT

Under section 78 of the Environmental Protection Act, 1990 and regulations and subject to the limitations thereof, a permit is hereby issued

XXXXXXXXXXXXXXXXXXXXXXXXXXXX
XXXXXXXXXXXXXXXXXXXXXXXXXXXX

for the use and operation of the Class 4 Sewage System Installed/Altered under Certificate of Approval E-16

such system being located on Lot 62 Conc. 2 Plan 508 Sub lot _____

Township/Municipality ELDON County VICTORIA

Inspected and Recommended by [Signature]

Kawartha Lakes, Mandatory Maintenance Assessment, October 16, 2021



Development Services/ Building and Septic Division
180 Kent Street West, Lindsay ON K9V 2Y6
P: 705-324-9411 Ext. 1882
Website: www.kawarthalakes.ca

October 15, 2021

~~XXXXXXXXXXXXXXXXXXXXXXXXXXXX~~
26 GREENWOOD CRES
WOODVILLE, ON K0M 2T0

~~XXXXXXXXXXXXXXXXXXXXXXXXXXXX~~

**RE: Mandatory Maintenance Assessment
26 Greenwood
Plan 508 Lot 62
City of Kawartha Lakes
Roll No. 165116005003567**

On September 16, 2021 a sewage system maintenance assessment was completed for your property as per the requirements of Division C, Part 1, Section 1.10 of the Ontario Building Code. This assessment was completed to determine whether the system is in substantial compliance with the Operation and Maintenance requirements outlined in Section 8.9 of Division B of the Ontario Building Code.

At the time of inspection, no issues were identified relating to the operation and maintenance of the sewage system.

The assessments are mandated to be completed every 5 years and thus your next inspection will be completed in the the 2026 evaluations.

Should you have any questions or concerns, please contact our office at 705-324-9411 Ext. 1882 or via email at aelmhirst@kawarthalakes.ca

Sincerely,

Anne Elmhirst, B.A. Sc., B.Sc.(H), C.P.H.I (C)
Supervisor – Part 8 Sewage Systems
Developmental Services – Building and Septic Division
City of Kawartha Lakes

Shepherd Environmental Services, Pumping Septic Tank, October 3, 2023



SHEPHERD ENVIRONMENTAL SERVICES

6798 Hwy 35, P.O. Box 68
Coboconk, Ontario K0M 1K0

Telephone: 705-454-3744 • 705-454-3627
705-887-1503 • 705-286-1178
Fax: 705-454-8700

CUSTOMER:

~~XXXXXXXXXXXXXXXXXXXX~~
26 GREENWOOD CRES.
WOODVILLE ON K0M 2T0

DIRECTIONS:


26 GREENWOOD CRES.
BOLSOVER RD. TO ARMITAGE AVE.
TO TRENT RIVER RD. N.

INV. NO. 0000145881
DATE: Oct-03-23
CUST. NO. 028996

~~XXXXXXXXXXXXXXXXXXXX~~

~~XXXXXXXXXXXXXXXXXXXX~~ TERMS: PAYABLE ON RECEIPT
ON VISA • M/C • DEBIT • ETRANSFER
EMT: Lshepherd@shepherdenvironmental.ca
Quote Invoice Number

ITEM NUMBER	DESCRIPTION	AMOUNT
SEPTIC5-01	PUMPING SEPTIC TANK	256.64
<p> SHEPHERD ENVIRONMENTAL 6798 HWY 35 COBOCONK, ON K0M1K0 7054543744 SALE PHONE ORDER REF#: 00000010 RR#: 00000010 08-13-00 CVD: M MID: 5674622 TD: 003 Batch #: 277001 10/04/23 ORDER#: 26596 APPR CODE: 080531 VISA *****0960 Manual CNP *** </p>		<p> AMOUNT \$290.00 APPROVED I AGREE TO PAY ABOVE TOTAL AMOUNT IN ACCORDANCE WITH CARD ISSUER'S AGREEMENT (MERCHANT AGREEMENT IF CREDIT VOUCHER) RETAIN THIS COPY FOR STATEMENT VERIFICATION THANK YOU! / MERCI CUSTOMER COPY </p>
<p> HST # R10 Material on site pertaining to this invoice remains the property of Shepherd Environmental Services until paid in full. Work done close to trees, flower beds, patios, sidewalks, etc. done at customer's risk only. 2% INTEREST CHARGED PER MONTH ON ACCOUNTS OVER 30 DAYS. </p>		<p> HST 33.36 TOTAL: \$290.00 </p>
<p>PAYMENT METHOD:</p>		



CUSTOMER COPY

INVOICE

DRIVER: _____